

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7165-0028:185 Page 1 of 1

CATEGORY: Control Unit (Non-High Rise)

LISTEE: Notifier, A Pittway Company, One Fire-Lite Place, Northford, CT 06472-1653
Contact: Lawrence Flood (203) 484-1200

DESIGN: Model SFP-1024 fire alarm control unit. Power limited; non-coded, local, remote station and central station service; manual, automatic, waterflow and sprinkler supervisory service. Refer to listee's data sheet for additional detailed product description and operational considerations. System components:

SFP-1024	Control Unit
CAC-10F	Class A Connector
PRT-24	Printer Interface Module
NAC-REM	Bell/Relay Expander Module
XRM-24	Transformer
LED-10IM	Annunciator Interface Module

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as a fire alarm control unit for use with separately listed electrically and functionally compatible initiating and indicating devices.

*This control unit can generate the temporal code pattern fire alarm signal as required per NFPA 72, 1996 Edition. Refer to manufacturer's Installation Manual for details.

NOTE: For **Fire Alarm Verification Feature**, the maximum retard/Reset/Restart shall be adjusted to 30 seconds or less.

XLF: 7165-0075:177

*Rev. 08-26-99



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

MAY 7, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager